



Clow Valve Co.

902 South 2nd Street  
Oskaloosa, IA 52577

Telephone: 641 673-8611  
Fax: 641 673-8269

**Effective 2022 (January)**

**Subject: Certificate of Compliance – Eddy Fire Hydrant**

Clow Valve Company manufactures the Eddy model dry-barrel fire hydrant in the United States of America with compliance to the following criteria.

*Product*

- AWWA C502, Dry-Barrel Fire Hydrants (250psi rating)
- AWWA C550, Protective Interior Coatings for Valves and Hydrants
- FM Class Number 1510, Fire Hydrants (Dry-Barrel Type) for Private Fire Service (250psi rating)
- NFS/ANSI 61, Drinking Water System Components – Health Effects (with Annex G)
- NSF/ANSI 372, Drinking Water System Components – Lead Content

*Materials (where applicable)*

- Ductile Iron: ASTM A536 (Grade 65-45-12 minimum strength)
- Gray Iron: ASTM A126 (Class B)
- Copper Alloy:
  - ASTM B16 (C36000)
  - ASTM B98 (C65500)
  - ASTM B584 (C83600, C86700, C87610, C87850, C89833)
  - ASTM B763 (C86700, C87610, C99500)

Compliance with other standards, such as those related to end joint connections, is dictated by compliance with standards listed above. If you have any questions, please call (800) 829-2569 for assistance.

Sincerely,

Doug Peirce  
Engineering & Quality Manager