



Clow Valve Co.

902 South 2nd Street  
Oskaloosa, IA 52577

Telephone: 641 673-8611  
Fax: 641 673-8269

**Effective 2018 (January)**

**Subject: Certificate of Compliance – Double Disc Gate Valve (L14)**

Clow Valve Company manufactures the C500 Double Disc Gate Valve (L14) in the United States of America with compliance to the following criteria.

*Product*

- AWWA C500, Metal-Seated Gate Valves for Water Supply Service (2” – 12” with 200psi rating 14” – 48” with 150psi rating)
- AWWA C550, Protective Interior Coatings for Valves and Hydrants
- UL 262, Gate Valves for Fire-Protection Service available (2.5” – 10” NRS with 200 psi rating, 12” – 14” NRS with 175psi rating)
- FM Class Number 1120/1130, Fire Service Water Control Valves available (2.5” – 14” NRS with 200psi rating)
- NFS/ANSI 61, Drinking Water System Components – Health Effects

*Materials (where applicable)*

- Ductile Iron: ASTM A536 (Grade 65-45-12 minimum strength)
- Gray Iron: ASTM A126 (Class B)
- Copper Alloy:
  - ASTM B16 (C36000)
  - ASTM B98 (C65500)
  - ASTM B584 (C83600, C86700, C87610, C87850, C89833)
  - ASTM B763 (C86700, C87610, C99500)

Compliance with other standards, such as those related to end joint connections, is dictated by compliance with standards listed above. If you have any questions please call (800) 829-2569 for assistance.

Sincerely,

Doug Peirce  
Engineering & Quality Manager